

Table 12.15.1 SUDS PRESSURE RELIEF VENTS	
Drain Size (inches)	Relief Vent Size (inches)
1-1/2	2
2	2
3	2
4	3
5	4
6	5
8	6

## 12.16 SIZE AND LENGTH OF VENTS

Table 12.16 SIZE AND LENGTH OF VENTS										
Size of Fixture Drain, Drainage Stack, or Building Drain (inches)	Drainage Fixture Units Connected	Diameter of Vent Required (inches) for the Maximum Length of Vent (feet)								
		1-1/4"	1-1/2"	2"	2-1/2"	3"	4"	5"	6"	8"
1-1/4"	1	(1)								
1-1/2"	8	50	150							
2"	12	30	75	200						
2"	20	26	50	150						
3"	10		30	100	200	600				
3"	30			60	200	500				
3"	60			50	80	400				
4"	100			35	100	260	1000			
4"	200			30	90	250	900			
4"	500			20	70	180	700			
5"	200				35	80	350	1000		
5"	500				30	70	300	900		
5"	1100				20	50	200	700		
6"	350					50	200	400	1300	
6"	620					30	125	300	1100	
6"	960					24	100	250	1000	
6"	1900					20	70	200	700	
8"	600						50	150	500	1300
8"	1400						40	100	400	1200
8"	2200						30	80	350	1100
8"	3600						25	60	250	800
10"	1000							75	125	1000
10"	2500							50	100	500
10"	3800							30	80	350
10"	5600							25	60	250

### NOTES FOR TABLE 12.16

(1) The length of the vent is not limited.